



88 Empire Drive • St. Paul, Minnesota • 55103
 (651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

June 21, 2012

Supplier: Hilti Entwicklungsgesellschaft mbH
 BU Anchors
 Hiltistrasse 6
 86916 Kaufering
 GERMANY

Sample Description: Hilti CFS-S SIL Firestop Silicone Sealant (Medium Density)

Date Tested: May 23, 2012

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
LEED 2009 (LEED 3.0) LEED 2.2 IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	Hilti CFS-S SIL Silicone Sealant (Medium Density)
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
Architectural Sealant; VOC Limit: 250 g/L	
	Product contains: 0.36 g/L of VOC

Tom Barrett
 Vice President/Strategic Analytical Services

Kelly French
 Chemist III/Dept. Manager