




Classified by
Underwriters Laboratories, Inc.
to UL 1479 and CAN/ULC-S115

System No. W-L-1551


ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating - 1 Hr	F Rating - 1 Hr
T Rating - 0 Hr	FT Rating - 0 Hr
	FH Rating - 1 Hr
	FTH Rating - 0 Hr

WL 1551



- Wall Assembly — The 1 hr fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described within V497 Wall and Partition Designs in the UL Fire Resistance Directory and shall incorporate the following construction features:
 - Studs — Wall framing shall consist of steel channel studs fabricated from min 25 MSG corrosion-protected steel, min 3-5/8 in. wide, min 1-1/4 in. flanges, spaced a max of 24 in. OC. Studs to be cut 3/8 to 3/4 in. less than assembly height.
 - Gypsum Board* — Nom 5/8 in. (16 mm) thick gypsum board as specified in the V497 Wall and Partition Design. Max diam of opening is 3 in. (76 mm).
- Through Penetrants — One metallic pipe or tubing to be installed either concentrically or eccentrically within the firestop system. Pipe or tubing to be rigidly supported on both sides of wall assembly. The annular space shall be min 1/4 in. (6 mm) to max 5/8 in. (16 mm). The following types and sizes of metallic pipes or tubing may be used:
 - Steel Pipe — Nom 2 in. (51 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.
 - Iron Pipe — Nom 2 in. (51 mm) diam (or smaller) cast or ductile iron pipe.
 - Conduit — Nom 2 in. (51 mm) diam (or smaller) rigid steel conduit or electrical metallic tubing (EMT).
 - Copper Tubing — Nom 2 in. (51 mm) diam (or smaller) Type L (or heavier) copper tubing.
 - Copper Pipe — Nom 2 in. (51 mm) diam (or smaller) Regular (or heavier) copper pipe.
- Fill, Void or Cavity Material* - Sealant — Min 1-1/4 in. (32 mm) thickness of fill material applied within the annulus, installed from one or both sides of wall assembly, flush with both surfaces of gypsum board.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-ONE MAX Intumescent Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
November 13, 2018