




Classified by  
Underwriters Laboratories, Inc.  
to UL 1479 and CAN/ULC-S115

# System No. C-AJ-1534

F Rating - 2 Hr

T Rating - 0 Hr

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating — 2Hr	F Rating — 2 Hr
T Ratings — 0 Hr	FT Ratings — 0 Hr
	FH Rating — 2 Hr
	FTH Rating — 0 Hr



1. Floor or Wall Assembly — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) concrete. Wall may also be constructed of any UL Classified Concrete Blocks\*. Max diam of opening is 10 in. (254 mm).  
See Concrete Blocks (CAZT) category in Fire Resistance Directory for names of manufacturers
  2. Through Penetrant — One metallic pipe, conduit or tubing to be installed concentrically or eccentrically within opening. The annular space between the through penetrant and the periphery of opening shall be min 0 in. (point contact) to max 1-7/8 in. (48 mm). Through penetrant to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of through penetrants may be used:
    - A. Steel Pipe — Nom 8 in. (203 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.
    - B. Iron Pipe — Nom 8 in. (203 mm) diam (or smaller) cast or ductile iron pipe.
    - C. Copper Tubing — Nom 4 in. (102 mm) diam (or smaller) Type L (or heavier) copper tube.
    - D. Copper Pipe — Nom 4 in. (102 mm) diam (or smaller) Regular (or heavier) copper pipe.
    - E. Conduit — Nom 4 in. (102 mm) diam (or smaller) steel electrical metallic tubing or nom 6 in. (152 mm) rigid steel conduit.
  3. Fill, Void or Cavity Materials\* - Sealant — Min 1/2 in. (13 mm) thickness of fill material within the annulus, flush with bottom surface of floor or with both surfaces of wall. Min 1/2 in. (13 mm) bead of fill material applied at the concrete/through penetrant interface on bottom surface of floor or both surfaces of wall.
- HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-ONE Sealant or FS-ONE MAX Intumescent Sealant.

\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Reproduced by HILTI, Inc. Courtesy of  
Underwriters Laboratories, Inc.  
January 08, 2015