



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	4485-1200:0503
<b>CATEGORY:</b>	4485 - OPENING PROTECTION (FIRESTOPPING)
<b>LISTEE:</b>	HILTI, INC. 5400 S 122nd East Ave., Tulsa, OK, 74146 Contact: Winston, Matthew (214) 803-5721 (918) 254-1679 Email: matthew.winston@hilti.com
<b>DESIGN:</b>	Model CFS-COS Firestop Composite Sheet. Refer to listee's printed data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.
<b>RATING:</b>	
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, type identification and UL label.
<b>APPROVAL:</b>	Listed as a fill, void or cavity material when constructed and installed in accordance with UL Fire Resistance Directory. C-AJ-0155, C-AJ-0157, C-AJ-2885, C-AJ-3345, C-AJ-4107, C-AJ-7195, C-AJ-8250, C-AJ-8252, C-BJ-3042, W-J-8056, W-J-8078, W-L-2741, W-L-8105, W-L-8125.
<b>NOTES:</b>	

10-09-19 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/25/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division