

CERTIFICATE OF COMPLIANCE

Certificate Number 20171019-R15431
Report Reference R15431
Issue Date 2017-October-19

Issued to: Hilti Construction Chemicals, Div of Hilti Inc.
7250 Dallas Pky, Legacy Tower Ste 1000
Plano, TX 75024 USA

**This is to certify that
representative samples of**

Firestop Devices
Firestop Devices Certified for Canada

CP 653 2" and/or 4" Speed Sleeves and CP 653 BA 2"
and/or 4" Speed Sleeves for use in Through-Penetration
Firestop Firestop Systems as currently described in the UL
Fire Resistance Directory and in the Products Certified for
Canada Directory.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1479, "Fire Tests of Through-Penetration
Firestops,"
CAN/ULC-S115-11, "Standard Method of Fire Tests of
Firestop Systems."

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

