



88 Empire Drive • St. Paul, Minnesota • 55103
 (651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

May 11, 2011

Supplier: Hilti Entwicklungsgesellschaft mbH
 BU Chemicals
 Hiltistrasse 6
 86916 Kaufering
 GERMANY

Sample Description: Hilti CFS-SP WB Firestop Joint Spray

Date Tested: May 10, 2011

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
LEED 2009 (LEED 3.0) LEED 2.2 IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	Hilti CFS-SP WB Firestop Joint Spray
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
Architectural Sealant; VOC Limit: 250 g/L	

William Welbes
Vice President of Laboratory Operations

Tom Barrett
Senior Chemist