





Classified by
Underwriters Laboratories, Inc.
to UL 1479 and CAN/ULC-S115

System No. F-A-7026

FA 7026

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating — 3 Hr	F Rating — 3 Hr
T Rating — 1/4 Hr	FT Rating — 1/4 Hr
	FH Rating — 3 Hr
	FTH Rating — 1/4 Hr



1. Floor Assembly — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete.
2. Firestop Device* — Cast in place firestop device with optional accessories including sleeve extensions permanently embedded during concrete placement or grouted in concrete floor assembly in accordance with accompanying installation instructions.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CFS-CID U 6"
3. Steel Duct — Nom 6 in. (152 mm) diam (or smaller) No. 28 gauge (or heavier).
4. Fill, Void or Cavity Material* Putty (Not Shown) — When steel duct is less than nominal 6 in. (152 mm) diam, a min 1 in. (25 mm) thickness of fill material shall be applied within annulus, flush with top surface of device.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP 618 Firestop Putty Stick
- 4A. Packing Material (Not Shown) — As an alternate to Item 4, min 4 in. (102 mm) thickness of min 4 pcf (64 kg/m³) mineral wool insulation firmly packed to the fullest extent possible within annulus flush with top surface of device.

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
September 27, 2023