UL/cUL SYSTEM NO. C-AJ-7151 INSULATED DUCT (THERMAL CERAMICS) THROUGH CONCRETE FLOOR/WALL OR BLOCK WALL ASSEMBLY CAJ7151a.123113 F-RATING = 3-HR. T-RATING = 3-HR. **TOP VIEW SECTION A-A** 5 Sheet Drawing No. 1 of 2 HILTI, Inc. **CAJ** Scale 1/16" = 1" Tulsa, Oklahoma USA (800) 879-8000 Date 7151a **Hilti Firestop Systems** Dec. 31, 2013 Saving Lives through Innovation and Education

UL/cUL SYSTEM NO. C-AJ-7151

INSULATED DUCT (THERMAL CERAMICS) THROUGH CONCRETE FLOOR/WALL OR BLOCK WALL ASSEMBLY

F-RATING = 3-HR. T-RATING = 3-HR. CAJ7151a.1231

- 1. CONCRETE FLOOR OR WALL ASSEMBLY (3-HR. FIRE-RATING):
 - A. LIGHTWEIGHT OR NORMAL WEIGHT CONCRETE FLOOR (MINIMUM 4-1/2" THICK).
 - B. LIGHTWEIGHT OR NORMAL WEIGHT CONCRETE WALL (MINIMUM 4-3/4" THICK).
 - C. ANY UL/cUL CLASSIFIED CONCRETE BLOCK WALL.
- 2. SHEET METAL DUCT TO BE ONE OF THE FOLLOWING:
 - A. CARBON STEEL AIR DUCT (MIN. 26 GA.) WITH MAXIMUM PERIMETER DIMENSION OF 216" AND A MAXIMUM INDIVIDUAL DIMENSION OF 84".
 - B. CARBON STEEL GREASE DUCT (MIN. 16 GA.) WITH MAXIMUM PERIMETER DIMENSION OF 96" AND A MAXIMUM INDIVIDUAL DIMENSION OF 36".
- 3. TWO LAYERS NOMINAL 1-1/2" THICK FIREMASTER FAST WRAP XL, FIREMASTER FASTWRAP+, OR PYROSTAT DUCT WRAP XL (MANUFACTURED BY THERMAL CERAMICS) INSTALLED PER MANUFACTURER'S INSTRUCTIONS.
- 4. MINIMUM 1/2" WIDE x 0.015" THICK CARBON STEEL BANDING STRAPS SPACED 12" OC AND 1-1/2" FROM TRANSVERSE JOINTS OF DUCT WRAP.
- 5. MINIMUM 4" THICKNESS MINERAL WOOL SAFING (MIN. 3 PCF DENSITY) OR UNFACED DUCT WRAP MATERIAL TIGHTLY PACKED.
- 6. MINIMUM 1/2" DEPTH HILTI CFS-S SIL GG FIRESTOP SILICONE SEALANT OR HILTI CFS-S SIL SL FIRESTOP SILICONE SEALANT (FLOORS ONLY).

NOTES: 1. MAXIMUM AREA OF OPENING = 24 SQ. FT., WITH A MAXIMUM DIMENSION OF 96".

2. MINIMUM 1/2" DEPTH HILTI CFS-S SIL GG FIRESTOP SILICONE SEALANT IS REQUIRED ON BOTH SIDES OF A WALL ASSEMBLY.



HILTI, Inc. Tulsa, Oklahoma USA (800) 879-8000
 Sheet
 2 of 2

 Scale

 Date
 Dec. 31, 2013

CAJ 7151a