




Classified by
Underwriters Laboratories, Inc.
to UL 1479 and CAN/ULC-S115

System No. F-A-4003

FA 4003

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating — 2 Hr	F Rating — 2 Hr
T Rating — 0 Hr	FT Rating — 0 Hr
	FH Rating — 2 Hr
	FTH Rating — 0 Hr



1. Floor or Wall Assembly — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete. Max size of opening is 30 by 9 in. (762 by 229 mm).
2. Cable Tray* — Max 24 in. (610 mm) wide by 6 in. (152 mm) deep open-ladder steel or aluminum cable tray. The annular space between cable tray and periphery of opening shall be min 0 in. (0 mm) (point contact) to max 6 in. (152 mm). Cable tray to be rigidly supported on both sides of the floor assembly.
CABLOFIL INC — Type P-W
3. Cables — Aggregate cross-sectional area of cable tray to be max 67 percent of the cross-sectional area of the cable tray. Any combination of the following types and sizes of cables may be used:
 - A. Max 300 pair No. 24 AWG telephone cable with polyvinyl chloride (PVC) insulation and jacket.
 - B. Max 500 kcmil single conductor copper power cable with PVC jacket material.
 - C. Multiple fiber optical communication cable jacketed with PVC and having a max OD of 1/2 in. (12 mm).
 - D. Max 3/C No. 12 AWG steel clad cable with copper conductors and PVC insulation material.
 - E. Max 7/C 12 AWG copper power cable with PVC jacket material.
4. Firestop System — The firestop system shall consist of the following:
 - A. Packing Material — Min 4 in. (102 mm) thickness of 4 pcf (64 kg/m³) mineral wool batt insulation tightly packed into the opening as a permanent form. Packing material to be recessed from top surface of floor to accommodate the required thickness of fill material.
 - B. Fill, Void or Cavity Material — Sealant — Min 1/4 in. (6 mm) thickness of fill material applied within the annulus flush with the top surface of the floor.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP 604, CFS-S SIL GG or CFS-S SIL SL Sealant

*Bearing the UL Classification Mark



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
December 27, 2013