

RESIDENTIAL HOLLOW CORE		SYSTEM	DESCRIPTION
6.1	FLOORS 4" THICK	F-8-100	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		F-8-200	INSULATED AB/FVC & GLASS FIBER METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
6.2	FLOORS OR WALLS 4" THICK	CAJ-200	METAL PIPE THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-210	MULTIPLE METAL PIPE THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-210P	PLASTIC PIPE THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-210F	PLASTIC PIPE THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-200	METAL PIPE WITH AB/FVC INSULATION THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-200P	METAL PIPE WITH GLASS FIBER OR CALCIUM SILICATE INSULATION THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-200	METAL DUCT (WITHOUT DAMPER) THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-200	ROUND SHEET METAL DUCT THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-210	SHEET METAL DUCT WITH GLASS FIBER INSULATION THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-210	CABLE BUNDLE THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-200	MULTIPLE PENETRATIONS THROUGH CONCRETE OR MASONRY (2HR)
		CAJ-200	ELECTRICAL BUSWAY THROUGH CONCRETE OR MASONRY (2HR)
6.3	FLOORS OR WALLS 8" THICK	CB-100	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-100P	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-100	MULTIPLE METALLIC PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-100	PLASTIC PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-200	MULTIPLE NONMETALLIC PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-200	PEX LINES THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-200	CABLE BUNDLE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-200	INSULATED GLASS FIBER METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-200	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2HR)
		CB-200	MULTIPLE METAL PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		CB-200	MULTIPLE METAL PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		CB-200	PLASTIC PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
6.4	GYPSUM WALL	WL-100	METAL PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	MULTIPLE METAL PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	PLASTIC PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	PLASTIC PIPE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	CABLE BUNDLE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	CABLE THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	PLASTIC PIPE WITH AB/FVC INSULATION THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	METAL PIPE WITH GLASS FIBER OR CALCIUM SILICATE INSULATION THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	METAL DUCT (WITHOUT DAMPER) THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	METAL DUCT THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	METAL DUCT WITH GLASS FIBER INSULATION THROUGH GYPSUM WALL ASSEMBLY (2HR)
		WL-100	MULTIPLE PENETRATIONS THROUGH GYPSUM WALL ASSEMBLY (2HR)
6.5	CONCRETE OR BLOCK WALL	WA-200	CABLE BUNDLE (1") (2HR)
6.6	MEMBRANE PENETRATION	MP-200	MEMBRANE PENETRATION IN GYPSUM WALL ASSEMBLY (2HR)
SHEET	JOINTS	SYSTEM	DESCRIPTION
6.7	GYPSUM WALL	BW-S-200	BOTTOM OF WALL JOINT (2HR)
		BW-S-200P	BOTTOM OF WALL JOINT (2HR)
6.8	GYPSUM SHAFT WALL	HW-D-200	TOP OF WALL JOINT (2HR)
		HW-D-200P	TOP OF WALL JOINT (2HR)
6.9	GYPSUM CHASE WALL	HW-D-200	TOP OF WALL JOINT (2HR)
		HW-D-200P	TOP OF WALL JOINT (2HR)
6.10	CONCRETE OR MASONRY WALL	HW-D-200	TOP OF WALL JOINT CONCRETE WALL OR MASONRY WALL ASSEMBLY (2HR)
		HW-D-200P	TOP OF WALL JOINT CONCRETE WALL OR MASONRY WALL ASSEMBLY (2HR)

**UL FIRE RESISTANCE DIRECTORY NOMENCLATURE**

**Through Penetrations**

First letter represents what is being penetrated	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s)	Example: CAJ1150
F = FLOOR W = WALLS C = FLOORS OR WALLS (COMBINED)	A = CONCRETE FLOORS WITH A MINIMUM THICKNESS LESS THAN OR EQUAL TO 5 IN  B = CONCRETE FLOORS WITH A MINIMUM THICKNESS GREATER THAN 5 IN  C = FRAMED FLOORS  E = FOR-CEILING ASSEMBLIES CONSISTING OF CONCRETE WITH MEMBRANE PROTECTION  J = CONCRETE OR MASONRY WALLS WITH A MINIMUM THICKNESS LESS THAN OR EQUAL TO 8 IN  L = FRAMED WALLS	0000 - 0999 BLANK OPENINGS  1000 - 1999 METAL PIPE, CONDUIT OR TUBING 2000 - 2999 NON METALLIC PIPE CONDUIT OR TUBING  3000 - 3999 CABLES 4000 - 4999 CABLE TRAYS  5000 - 5999 INSULATED PIPES 6000 - 6999 MISCELLANEOUS ELECTRICAL (BUSWAY) PROTECTION  7000 - 7999 MISCELLANEOUS MECHANICAL 8000 - 8999 MIXED PENETRATING ITEMS 9000 - 9999 RESERVED FOR FUTURE USE	C = FLOOR OR WALLPENETRATION  A = CONCRETE FLOORS 5" OR LESS  J = CONCRETE OR MASONRY WALLS 8" OR LESS  1150 = METAL PIPE, CONDUIT OR TUBING

**Joint Systems**

First letters identify the type of joint:	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s)	Example: HWD0757
CJ = CONTINUITY HEAD OF WALL FF = FLOOR TO FLOOR WW = WALL TO WALL FW = FLOOR TO WALL HW = HEAD TO WALL BW = BOTTOM OF WALL	S = NO MOVEMENT (STATIC)  D = ALLOWS MOVEMENT (DYNAMIC)	0000 - 0999 LESS THAN OR EQUAL TO 2"  1000 - 1999 GREATER THAN 2" AND LESS THAN OR EQUAL TO 6"  2000 - 2999 GREATER THAN 6" AND LESS THAN OR EQUAL TO 12"  3000 - 3999 GREATER THAN 12" AND LESS THAN OR EQUAL TO 24"  4000 - 4999 GREATER THAN 24"	HW = HEAD TO WALL  D = ALLOWS MOVEMENT (DYNAMIC)  0757 = LESS THAN OR EQUAL TO 2"

**Notes:**

- Refer to the following specifications for firestopping.
  - 07 84 00 Firestopping
  - 07 84 13 Penetration Firestopping
  - 07 84 43 Joints Firestopping
  - 22 00 00 Plumbing
  - 23 00 00 HVAC
  - 26 00 00 Electrical
  - 27 05 37 Communication Systems

For Quality Control requirements, refer to the Quality Control portion of the specification.

- Details shown are typical details. Always refer to the listed system detail for complete system requirements. If field conditions do not match requirements of details, approved alternate details shall be utilized. Design requirements, field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - \* Fire Rating (F-Rating)
  - \* Temperature Rating (T-Rating)
  - \* Leakage Rating (L-Rating)
  - \* Water Rating (W-Rating)
  - \* Annular Space
  - \* Percent Fill
  - \* Movement
  - \* Type and thickness of fire-rated construction.

- If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable subject to approval by the Authority Having Jurisdiction (AHJ). Contact Hilti Inc. for alternative systems or Engineering Judgment (800-879-8000). Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

- References:
  - \* 2017 Underwriter's Laboratories Fire Resistance Directory, Volumes 1 & 2.
  - \* NFPA 101 Life Safety Code
  - \* NFPA 70 – National Electric Code
  - \* All governing local and regional building codes.

- Firestop System installation must meet requirements of ASTM E-814 (UL 1479) tested assemblies that provide a fire rating equal or greater to that of construction being penetrated.

- All rated through-penetration assemblies shall be prominently labeled with a Hilti Firestop Label equipped with a QR code with the following information.
  - \* Warning! - Do Not Disturb
  - \* Through Penetration Firestop System
  - \* UL System # \* Product(s) used
  - \* Hourly Rating (F-Rating)
  - \* Installation Date
  - \* Contractor's Name

- For outlet boxes requiring protection, use only Wall Opening Protective Materials, category CLIV as classified by Underwriter's Laboratories, Fire Resistance Directory (Volume 1).

Current as of November 19, 2017. System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current Underwriter's Laboratories Fire Resistance Directory (volume 2.)

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 11-19-2017

REVISIONS: \_\_\_\_\_

SHEET NAME: \_\_\_\_\_  
Index of Drawings

SHEET NUMBER: \_\_\_\_\_









**System No. W-J-3215**

ANSI/UL 1479 (ASTM E814)	CANULC 5115	F Rating — 2 hr
L Rating at Ambient — Less than 1 CFM/Opening	FTI Rating — 1/2 and 2 hr (See Item 2)	FTI Rating — 2 hr
L Rating at 400°F — Less than 1 CFM/Opening	FTI Rating — 1/2 and 2 hr (See Item 2)	FTI Rating — 2 hr
L Rating at Ambient — Less than 1 CFM/Opening	FTI Rating — 1/2 and 2 hr (See Item 2)	FTI Rating — 2 hr
L Rating at 400°F — Less than 1 CFM/Opening	FTI Rating — 1/2 and 2 hr (See Item 2)	FTI Rating — 2 hr

**Hilti Firestop Systems**

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. October 16, 2015

Page 1 of 2

**System No. W-J-3215**

1. Wall Assembly — Min 6 in. (152 mm) thick lightweight or normal weight (150-150 pcf or 1600-2400 kg/m<sup>3</sup>) concrete. Wall may also be constructed of any UL Classified Concrete Block\*. Opening may be round, rectangular or irregular with a max diam or dimension of 1 in. (25 mm).

2. See Concrete Block (CB) category in the Fire Resistance Directory for names of manufacturers.

3. Cable — Single or split bundle of cables to be installed within the opening. Aggregate cross-sectional area of cables in opening to have a residual of min 7% to max 10%. The annular space between the cable bundle and the periphery of the opening to be min 0 in. (joint contact). Cables to be rigidly supported on both sides of the wall assembly. Any combination of the following types and sizes of cables may be used:

A. Max 3C No. 8 AWG 90 copper conductor cable (RHW) with PVC insulation and jacket

B. Max 12 No. 12 AWG 90 copper conductor control cable with PVC or PLF insulation and jacket

C. Max 100 pair No. 24 AWG (or smaller) copper conductor telecommunication cable with PVC or plenum rated insulation and jacketing

D. Max 4 No. 22 AWG (or smaller) Cat 5e or Cat 6 copper cables with PVC or plenum rated insulation and jacketing

E. Type R/UL Classified cable with full rated annular of PVC insulation and jacketing having a max outside diameter of 1/4 in. (3 mm)

F. Max 24 fiber optic cable with polyimide sheath (PVC or polyethylene PE jacket and insulation)

G. Through penetrating module — Max two copper conductor No. 18 AWG (or smaller) Power or Non-Power Limited Fire Alarm Cable with or without a jacket under a single entry.

H. Maximum 3C No. 10 AWG metal-clad cable.

The Hours, FTI and FTI Ratings of the firestop system are 2 hr except that for cable type B) and C), the ratings are 1/2 hr. For blank openings with no penetrations, the F, FT, FTI and FTI Ratings are 2 hr.

2. Fit, Void or Cavity Sealant\* — Min 1/8 in. (3 mm) thick solid, with one seam at radius. Paper backing of disc to be removed and disc firmly pressed around the cable bundle tapping from 5 mm into cables to completely cover opening and firmly pressed to lap onto the wall around perimeter of opening. Disc must be firmly pressed and sealed tight. Disc to be installed at both surfaces of wall.

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC. — CFS-D 1 Firestop Cable Disc

\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

**Hilti Firestop Systems**

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. October 16, 2015

Page 2 of 2

**Notes:**

1. Refer to the following specifications for firestopping.
  - a. 07 84 00 Firestopping
  - b. 07 84 13 Penetration Firestopping
  - c. 07 84 43 Joints Firestopping
  - d. 22 00 00 Plumbing
  - e. 23 00 00 HVAC
  - f. 26 00 00 Electrical
  - g. 27 05 37 Communication Systems

For Quality Control requirements, refer to the Quality Control portion of the specification.

2. Details shown are typical details. Always refer to the listed system detail for complete system requirements. If field conditions do not match requirements of details, approved alternate details shall be utilized. Design requirements, field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - \* Fire Rating (F-Rating)
  - \* Temperature Rating (T-Rating)
  - \* Leakage Rating (L-Rating)
  - \* Water Rating (W-Rating)
  - \* Annular Space
  - \* Percent Fill
  - \* Movement
  - \* Type and thickness of fire-rated construction.

3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable subject to approval by the Authority Having Jurisdiction (AHJ). Contact Hilti Inc. for alternative systems or Engineering Judgment (800-879-8000). Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

4. References:
  - \* 2017 Underwriter's Laboratories Fire Resistance Directory, Volumes 1 & 2.
  - \* NFPA 101 Life Safety Code
  - \* NFPA 70 – National Electric Code
  - \* All governing local and regional building codes.

5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479) tested assemblies that provide a fire rating equal or greater to that of construction being penetrated.

6. All rated through-penetration assemblies shall be prominently labeled with a Hilti Firestop Label equipped with a QR code with the following information.
  - \* Warning! - Do Not Disturb Through Penetration Firestop System
  - \* UL System # \* Product(s) used
  - \* Hourly Rating (F-Rating)
  - \* Installation Date
  - \* Contractor's Name

7. For outlet boxes requiring protection, use only Wall Opening Protective Materials, category CLIV as classified by Underwriter's Laboratories, Fire Resistance Directory (Volume 1).

*Current as of November 19, 2017. System details subject to change without notice.*

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current Underwriter's Laboratories Fire Resistance Directory (volume 2.)

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 11-19-2017

REVISIONS: \_\_\_\_\_

SHEET NAME: Residential - Hollow Core - Concrete or Block Wall

SHEET NUMBER: \_\_\_\_\_

**Wall Opening Protective Materials (CLIV, CLIV7)**

1 or 2 Hr Gypsum Wall Assembly (2 Hr Show)

Power Cable

1/8" Thick CP617 or CP5-P-PA Firestop Putty Pad

Wood Stud or Steel Stud (Not Shown)

UL Listed Non-Metallic Outlet Box (Refer to UL Listing) Or UL Listed Metallic Outlet Box (Refer to UL Listing)

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. December 07, 2018

Page 1 of 5

**Wall Opening Protective Materials (CLIV, CLIV7)**

1 or 2-Hr Gypsum Wall Assembly (2-Hr Show)

Steel Stud or Wood Stud (Not Shown)

Power Cable

Firestop Box Insert

UL Listed Non-Metallic Outlet Box (Refer to UL Listing) or UL Listed Metallic Outlet Box (Refer to UL Listing)

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. December 07, 2018

Page 2 of 5

**Wall Opening Protective Materials (CLIV, CLIV7)**

Resistive Directory, Putty pads and boxes use 1/8" thick CP617 or CP5-P-PA Firestop Putty Pads for use with fast device UL Listed Metallic Outlet Boxes installed with steel stud rings or UL Listed Nonmetallic Outlet Boxes in framed wall assemblies as specified below. When protective material is used in outlet boxes on both sides of the wall as directed, the reciprocal separation between outlet boxes on opposite sides of the wall will meet the 24 in. provided that the boxes are not installed back-to-back (unless otherwise indicated). Installation shall comply with the National Electrical Code (NEC/IFC) and the manufacturer's instructions. The boxes are not intended to be used in fire-rated walls. The boxes are not intended to be used in fire-rated walls unless otherwise specified.

CP 617 or CP5-P-PA Firestop Putty Pads, for use with max 4 by 4 by 4 in., 1/2 in. deep stud-rod UL Listed Metallic Outlet Boxes installed with steel stud rings or UL Listed Nonmetallic Outlet Boxes in framed wall assemblies as specified below. When protective material is used in outlet boxes on both sides of the wall as directed, the reciprocal separation between outlet boxes on opposite sides of the wall will meet the 24 in. provided that the boxes are not installed back-to-back (unless otherwise indicated). Installation shall comply with the National Electrical Code (NEC/IFC) and the manufacturer's instructions. The boxes are not intended to be used in fire-rated walls unless otherwise specified.

CP 617 or CP5-P-PA Firestop Putty Pads, for use with max 4 by 4 by 4 in., 1/2 in. deep stud-rod UL Listed Metallic Outlet Boxes installed with steel stud rings or UL Listed Nonmetallic Outlet Boxes in framed wall assemblies as specified below. When protective material is used in outlet boxes on both sides of the wall as directed, the reciprocal separation between outlet boxes on opposite sides of the wall will meet the 24 in. provided that the boxes are not installed back-to-back (unless otherwise indicated). Installation shall comply with the National Electrical Code (NEC/IFC) and the manufacturer's instructions. The boxes are not intended to be used in fire-rated walls unless otherwise specified.

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. December 07, 2018

Page 3 of 5

**Wall Opening Protective Materials (CLIV, CLIV7)**

CP 617 or CP5-P-PA Firestop Putty Pads, for use with max 4 by 4 by 4 in., 1/2 in. deep stud-rod UL Listed Metallic Outlet Boxes installed with steel stud rings or UL Listed Nonmetallic Outlet Boxes in framed wall assemblies as specified below. When protective material is used in outlet boxes on both sides of the wall as directed, the reciprocal separation between outlet boxes on opposite sides of the wall will meet the 24 in. provided that the boxes are not installed back-to-back (unless otherwise indicated). Installation shall comply with the National Electrical Code (NEC/IFC) and the manufacturer's instructions. The boxes are not intended to be used in fire-rated walls unless otherwise specified.

CP 617 or CP5-P-PA Firestop Putty Pads, for use with max 4 by 4 by 4 in., 1/2 in. deep stud-rod UL Listed Metallic Outlet Boxes installed with steel stud rings or UL Listed Nonmetallic Outlet Boxes in framed wall assemblies as specified below. When protective material is used in outlet boxes on both sides of the wall as directed, the reciprocal separation between outlet boxes on opposite sides of the wall will meet the 24 in. provided that the boxes are not installed back-to-back (unless otherwise indicated). Installation shall comply with the National Electrical Code (NEC/IFC) and the manufacturer's instructions. The boxes are not intended to be used in fire-rated walls unless otherwise specified.

CP 617 or CP5-P-PA Firestop Putty Pads, for use with max 4 by 4 by 4 in., 1/2 in. deep stud-rod UL Listed Metallic Outlet Boxes installed with steel stud rings or UL Listed Nonmetallic Outlet Boxes in framed wall assemblies as specified below. When protective material is used in outlet boxes on both sides of the wall as directed, the reciprocal separation between outlet boxes on opposite sides of the wall will meet the 24 in. provided that the boxes are not installed back-to-back (unless otherwise indicated). Installation shall comply with the National Electrical Code (NEC/IFC) and the manufacturer's instructions. The boxes are not intended to be used in fire-rated walls unless otherwise specified.

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. December 07, 2018

Page 4 of 5

**Wall Opening Protective Materials (CLIV, CLIV7)**

Box Size	Type of Box and Cover Plate	Hourly Rating	Inset Type
4 x 4 x 2-1/8 in. deep	Metallic w/ steel cover plates	2-hour	US30, U400 or V400 - wood or steel studs
4 x 4 x 2-1/8 in. deep	Metallic w/ plastic cover plates	1-hour	US30, U400 or V400 - wood or steel studs
4 x 4 x 1-1/2 in. deep	Metallic w/ plastic cover plates	1-hour	US30 - wood studs

HLTI Firestop Box Insert, for use with max 2-1/8 x 4 x 2-1/8 in., deep UL Listed Metallic Outlet Boxes without internal clamps in 1 hr rated gypsum wallboard wall assemblies framed with max 1-1/2 in. deep wood or steel studs and constructed of materials and in the manner specified in the individual US30, U400 or V400 Series Wall and Partition Designs in the Fire Resistance Directory. Outlet boxes may be installed with steel cover plates. One 1-7/8 x 2-1/8 in. insert shall be used on the interior back wall of the outlet box in accordance with the instructions supplied with the product.

Box Size	Insets Used	Fire Rating	Wall Type
4-1/2 x 6-1/2 x 1-5/8 in. deep	Two 3-1/16 x 3-3/4 in. insets**	2-hour	US30, U400 or V400 - wood or steel studs
3-3/4 x 6-1/2 x 1-1/2 in. deep	One 3-1/16 x 3-3/4 in. inset and one 1-7/8 x 2-1/8 in. inset**	1-hour	US30, U400, or V400 - wood or steel studs

\*\* - Min 3/4 in. deep gasket rings installed over outlet box. After installation of gypsum board, room 1/4 in. thickness of Hilti FS-ONE Sealant or FS-ONE MAX Intumescent Sealant, bearing the UL Classification Marking for FS, Void or Cavity Materials, specified between the bases layer of wallboard and the gasket ring.

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. December 07, 2018

Page 5 of 5

- Notes:**
- Refer to the following specifications for firestopping.
    - 07 84 10 Firestopping
    - 07 84 13 Penetration Firestopping
    - 07 84 43 Joints Firestopping
    - d.22 00 00 Plumbing
    - e.23 00 00 HVAC
    - f.26 00 00 Electrical
    - g.27 05 37 Communication Systems

For Quality Control requirements, refer to the Quality Control portion of the specification.

- Details shown are typical details. Always refer to the listed system detail for complete system requirements. If field conditions do not match requirements of details, approved alternate details shall be utilized. Design requirements, field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - \* Fire Rating (F-Rating)
  - \* Temperature Rating (T-Rating)
  - \* Leakage Rating (L-Rating)
  - \* Water Rating (W-Rating)
  - \* Annular Space
  - \* Percent Fill
  - \* Movement
  - \* Type and thickness of fire-rated construction.

- If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable subject to approval by the Authority Having Jurisdiction (AHJ). Contact Hilti Inc. for alternative systems or Engineering Judgment (800-879-8000). Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

- References:
  - \* 2017 Underwriter's Laboratories Fire Resistance Directory, Volumes 1 & 2.
  - \* NFPA 101 Life Safety Code
  - \* NFPA 70 – National Electric Code
  - \* All governing local and regional building codes.

- Firestop System installation must meet requirements of ASTM E-814 (UL 1479) tested assemblies that provide a fire rating equal or greater to that of construction being penetrated.

- All rated through-penetration assemblies shall be prominently labeled with a Hilti Firestop Label equipped with a QR code with the following information.
  - \* Warning! - Do Not Disturb
  - \* Through Penetration Firestop System
  - \* UL System # \* Product(s) used
  - \* Hourly Rating (F-Rating)
  - \* Installation Date
  - \* Contractor's Name

- For outlet boxes requiring protection, use only Wall Opening Protective Materials, Category CLIV as classified by Underwriter's Laboratories, Fire Resistance Directory (Volume 1).

*Current as of November 19, 2017. System details subject to change without notice.*

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current 'Underwriters Laboratories Fire Resistance Directory (volume 2)'.

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 11-19-2017

REVISIONS: \_\_\_\_\_

SHEET NAME: Residential - Hollow Core - Membrane Penetration

SHEET NUMBER: \_\_\_\_\_





**System No. HW-D-0342**

ANSI/L2019	CANULC S115
Assembly Rating — 2 1/2 hr	F Rating — 2 hr
Normal Joint Width — 1 in.	FT Rating — 2 hr
Class I Movement Capabilities — 0% Compression and Extension	FTI Rating — 2 hr
L Rating At Ambient — Less Than 1 CFM/in <sup>2</sup>	FTII Rating — 2 hr
L Rating At 400 F — Less Than 1 CFM/in <sup>2</sup>	Normal Joint Width — 1 in.
	Class II Movement Capabilities — 0% Compression and Extension
	L Rating At Ambient — Less Than 1 CFM/in <sup>2</sup>
	L Rating At 400 F — Less Than 1 CFM/in <sup>2</sup>

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. March 20, 2015. Page: 1 of 2

**System No. HW-D-0342**

1. Floor Assembly — Min. 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete.

2. Steel Stud Assembly — The 2 1/2 hr-rated gypsum board steel stud wall assembly shall be constructed of the materials and in the manner described in the individual UL55, V500 or V500 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

A. Floor and Ceiling Runners — J-shaped runner, 2-1/2 in. (64 mm) wide with unequal legs of min. 1-1/4 in. (32 mm) and 2 in. (51 mm), fabricated from 24 MSG galv. steel. Runners positioned with short leg toward finished side of wall. Runners attached to structural supports with steel fasteners located not greater than 24 in. (61 mm) from ends and not greater than 24 in. (61 mm) OC.

B. Light Gauge Framing — Stiffened Ceiling Track — Openweb stiffened ceiling track shall consist of galv. steel channels with vertical flanges. Stiffened ceiling track used to accommodate steel "C" studs (Item 3C), attached to concrete at intervals of ceiling with steel fasteners spaced max. 24 in. (61 mm) OC.

CALIFORNIA EXPANDED METAL PRODUCTS CO. — CST  
 GIBBY CONSTRUCTION INNOVATIONS, INC. DSA SUBTRACK SYSTEMS — SUT-TRK  
 MARQUARDT, DIV. OF HANAU INDUSTRIES INC. — Type SLT  
 B1. Light Gauge Framing Members — (Optional Steel Sheet) — In an option, the steel studs (Item 3C) may incorporate vertical deflection stops for attachment to the ceiling runner (Item 2A) in accordance with the manufacturer's instructions.

THE STEEL NETWORK INC. — WNCp S13-130

C. Steel Stud — C-shaped studs, 2-1/2 in. (64 mm) wide by 1-1/2 in. (38 mm) deep, fabricated from min. 20 MSG galv. steel, cut to lengths 28 in. (713 mm) deep from top to ceiling height and spaced 24 in. (61 mm) OC. Stud used in floor runner or bottom and a runner on studded ceiling track at top. After installation of gypsum board fire panels (Item 2D), studs secured to flange of floor runner on finished side of wall only with No. 8 by 1/2 in. (13 mm) long self-drilling self-tapping wall stud steel screws as per midheight.

D. Gypsum Board — 1/2 in. (12.5 mm) thick 24 in. (61 mm) wide gypsum board fire panels as specified in the individual UL55 or V500 Series design. Panels cut 1 in. (25 mm) less in length than floor to ceiling height. Vertical edges mounted in "Y" shaped section of "C" stud, at the ends of the assembly, the end edge of the end panel are finished to the top of vertical runners (Item 2B) with 1-5/8 in. (41 mm) long Type 5 steel screws spaced max. 12 in. (305 mm) OC.

E. Gypsum Board — Gypsum board sheets, 1/2 in. (12.5 mm) thick, applied vertically or horizontally in two layers on finished side of wall as specified in the individual UL55 or V500 Series design. A max. 1 in. (25 mm) gap shall be maintained between the top of the gypsum board and the bottom surface of the concrete floor. The screws attaching the gypsum board layers to the "C" studs shall be spaced 1 in. (25 mm) below the bottom of the J-runner or studded ceiling track. No gypsum board attachment screws are to penetrate the ceiling runner and studded ceiling track.

3. Joint System — Max. separation between top of fire panel (Item 2D) and between top of gypsum board sheets (Item 2E) at line of installation of joint system is 1 in. (25 mm). The joint system is designed to accommodate a minimum panel compression and extension from its installed width. The joint system consists of the following:

A. Fire Insulation or Chalk Material — Spaced — Min. 1 in. (25 mm) depth of insulant to be installed to fill linear gap between top of gypsum board fire panel (Item 2D) and top inside surface of ceiling J-runner or studded ceiling track prior to installation of gypsum board (Item 2E) on finished side of wall. Min. 1 in. (25 mm) depth of insulant to be installed to fill linear gap between top of gypsum board sheets (Item 2E) and bottom of concrete floor.

HETI CONSTRUCTION CHEMICALS, DIV. OF HETI INC. — CP-050  
 \*Sealing the UL Classification Mark.

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. November 20, 2015. Page: 2 of 2

**System No. HW-D-0572**

ANSI/L2019	CANULC S115
Assembly Rating — 1 and 2 Hr (See Item 2)	F Rating — 1 and 2 Hr (See Item 2)
Normal Joint Width — 1-1/2 in.	FT Rating — 1 and 2 Hr (See Item 2)
Class I Movement Capabilities — 0% Compression and Extension	FTI Rating — 1 and 2 Hr (See Item 2)
	Normal Joint Width — 1-1/2 in.
	Class II Movement Capabilities — 0% Compression and Extension

1. Floor Assembly — Min. 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete. Floor may also consist of any fire-rated UL Classified hollow-core Precast Concrete Deck.\*

See Precast Concrete Deck (PCD) category in the Fire Resistance Directory for names of manufacturers.

2. Steel Stud Assembly — The 1 hr or 2 hr-rated gypsum board steel stud wall assembly shall be constructed of the materials and in the manner described in the individual UL55, V500 or V500 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

A. Floor and Ceiling Runners — J-shaped runner, steel sheet or wall to steel studs (Item 3C) with unequal legs of 1 in. (25 mm) and 2 in. (51 mm), fabricated from 24 MSG galv. steel. Runners positioned with short leg toward finished side of wall. Runners attached to steel wall fasteners located not greater than 2 in. (51 mm) from ends and not greater than 24 in. (61 mm) OC.

B. Ceiling Runner — Ceiling runner shall consist of galv. steel channel used to accommodate steel studs (Item 3C). Flange height of ceiling runner shall be min. 1-1/4 in. (32 mm) greater than max. extended joint width. Ceiling runner secured with steel fasteners located not more than 2 in. (51 mm) from ends and spaced not greater than 24 in. (61 mm) OC.

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. November 20, 2015. Page: 1 of 2

**System No. HW-D-0572**

B1. Light Gauge Framing\* — Stiffened Ceiling Runner — As an alternate to the ceiling runner in Item 2B, stiffened ceiling runner to consist of galv. steel channel with stiffened flanges used to accommodate steel studs (Item 3C). Flange height of stiffened ceiling runner shall be min. 1-1/4 in. (32 mm) greater than max. extended joint width. Stiffened ceiling runner secured with steel fasteners located not more than 2 in. (51 mm) from ends and spaced max. 24 in. (61 mm) OC.

GIBBY CONSTRUCTION INNOVATIONS, INC. DSA SUBTRACK SYSTEMS — SUT-TRK  
 CALIFORNIA EXPANDED METAL PRODUCTS CO. — CST  
 CLARKBROOK BUILDING SYSTEMS — Type SLT S13-F4  
 MARQUARDT, DIV. OF HANAU INDUSTRIES INC. — Type SLT  
 METALITE INC. — The System  
 SCAFCO STEEL STUD MANUFACTURING CO. — Studded Track  
 STEEL INDUSTRIES L.L.C. — True-Action Studded Track

C. Steel Stud — C-shaped studs, min. 2 in. (51 mm) wide by 1-1/2 in. (38 mm) deep, fabricated from 20 MSG galv. steel, cut to lengths 34 in. (863 mm) deep from top to ceiling height and spaced 24 in. (61 mm) OC.

D. Gypsum Board — Item 1 in. (25 mm) thick gypsum board fire panels, Panels cut 1-1/2 in. (38 mm) less in length than floor to ceiling height. Vertical edges mounted in finished section of "C" stud. At the ends of the assembly, the free edge of the end panels are attached to the long leg vertical runners (Item 2A) with 1-5/8 in. (41 mm) long Type 5 steel screws spaced max. 12 in. (305 mm) OC.

E. Gypsum Board — Item 1/2 in. (12.5 mm) thick gypsum board applied vertically in one or two layers for 1 hr and 2 hr fire rated assemblies, respectively. Panels cut 1-1/2 in. (38 mm) less in length than floor to ceiling height. The screws attaching the gypsum board layers to the "C" studs shall be located 1 to 1-1/2 in. (25 to 38 mm) below the bottom of the ceiling runner or studded ceiling track. No gypsum board attachment screws are to penetrate the ceiling runner or studded ceiling track.

The height of edge of the joint system is equal to the height of the top of the wall.

3. Joint System — Max. separation between bottom of floor and top of gypsum board at the line of installation of the joint system is 1/2 in. (13 mm). The joint system is designed to accommodate a min. 50 percent compression or extension from its installed width. The joint system consists of the following:

A. Forming Material\* — Min. 1/2 in. (12.5 mm) deep mineral wool batt insulation cut to a thickness twice larger than the distance between the top of the gypsum board and the bottom of the floor. Material compressed 50 percent and installed with ceiling runner above top of fire panel flush with the inside surface of the panel. Material compressed and installed on finished side of the wall between the top of the gypsum board and the bottom of the floor. Flush with the surface of the wall.

ROCK WOOL MANUFACTURING CO. — Deck Board  
 ROCK, INC. — SAFE  
 THERMAFLEX INC. — Type SFP

A1. Forming Material\* — Slips — As an alternate to Item 2A, the slips are slanted to a height twice larger than the distance between the top of the gypsum board and the bottom of the floor. Slips compressed 50 percent and installed with ceiling runner above top of fire panel flush with the inside surface of the panel. Slips compressed and installed on finished side of the wall between the top of the gypsum board and the bottom of the floor. Flush with the surface of the wall.

HETI CONSTRUCTION CHEMICALS, DIV. OF HETI INC. — CP 787 Speed Slips

B. Fire Insulation or Chalk Material — Min. 1 1/2 in. (38 mm) depth of insulant 108 in. or 2 1/2 in. (64 mm) thickness of fit material sprayed or blowed within stud cavity and on finished side of the stud wall to completely cover mineral wool forming material. Fit material to overlap a min. of 1/2 in. (13 mm) onto gypsum board and ceiling runner within stud cavity. Fit material to overlap a min. of 1/2 in. (13 mm) onto gypsum board and concrete on finished side of wall.

HETI CONSTRUCTION CHEMICALS, DIV. OF HETI INC. — CP-072 Firestop Spray or CFS-SP WB Firestop Joint Spray

\*Indicates such products shall bear the UL or UL Certification Mark for jurisdictions employing the UL or UL Certification (such as Canada), respectively.

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. November 20, 2015. Page: 2 of 2

**Notes:**

- Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
- Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - Minimum and maximum Width of Joints
  - Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
- If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
- References:
  - 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
  - Intertek Directory of Building Products
  - All governing local and regional building codes

Current as of November 19, 2017. System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current 'Underwriter's Laboratories Fire Resistance Directory (volume 2.)'

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 11-19-2017

REVISIONS: \_\_\_\_\_

SHEET NAME:  
Residential - Hollow Core - Gypsum Shaft Wall

SHEET NUMBER: \_\_\_\_\_

**System No. HW-D-0758**

ANSI A207.9	CANULC 5115
Assembly Rating — 1 and 2 hr (See Item 2)	F Rating — 1 and 2 hr (See Item 2)
Normal Joint Width — 1/2 to 3/8 in. (See Item 3)	FT Rating — 1 and 2 hr (See Item 2)
Class I or II Movement Capabilities — 50% Compression or Extension or 80% Compression Only	FN Rating — 1 and 2 hr (See Item 2)
	FTN Rating — 1 and 2 hr (See Item 2)
L Rating at 400° F — Less than 1 CFM/Lin Ft	Normal Joint Width — 1/2 to 3/8 in. (See Item 3)
	Class I or II Movement Capabilities — 50% Compression or Extension or 80% Compression Only
	L Rating at Ambient — Less than 1.55 L/lin Ft
	L Rating at 400° F — Less than 1.55 L/lin Ft

**UL** **UL**

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. December 21, 2015

Page 1 of 2

**System No. HW-D-0758**

1. Floor Assembly — Min. 4 1/2 in. (114 mm) thick reinforced (lightweight or normal weight) (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete. Floor may also be constructed of any 4 in. (102 mm) thick, U.C. Classified Hollowcore Precast Concrete Unit\*.

2. Wall Assembly — The 1 1/2 in. (38 mm) girth gasket mounted steel plate (steel plate) will assembly shall be constructed of the materials and in the manner described in the individual UL, VWD or VWD Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

A. Steel Floor and Ceiling Runners — Floor and ceiling runners of wall assembly shall consist of min. No. 20 gauge galv-steel channels sized to accommodate steel studs (See 2B). Flange height of ceiling runner shall be min. 1 1/2 in. (38 mm) greater than max. extended joint width. Ceiling runner secured to concrete floor slab with steel masonry anchors, steel fasteners spaced 24 in. (610 mm) OC.

A1. Light Gauge Framing\* — Stacked Ceiling Runner — As an alternate to the ceiling runner in Item 2A, stacked ceiling runner to consist of galv-steel channel with stacked flanges used to accommodate steel studs (See 2B). Stacked ceiling runner secured to concrete floor slab with steel masonry anchors and steel fasteners spaced 24 in. (610 mm) OC.

A2. Light Gauge Framing\* — Notched Ceiling Runner — As an alternate to the ceiling runner in Item 2A through 2A3, notched ceiling runner to consist of galv-steel channel with notched flanges used to accommodate steel studs (See 2B). Notched ceiling runner secured to concrete floor slab with steel masonry anchors or steel fasteners spaced max. 24 in. (610 mm) OC.

A3. Light Gauge Framing\* — Notched Ceiling Runner — As an alternate to the ceiling runner in Item 2A through 2A3, notched ceiling runner to consist of galv-steel channel with notched flanges used to accommodate steel studs (See 2B). Notched ceiling runner secured to concrete floor slab with steel masonry anchors or steel fasteners spaced max. 24 in. (610 mm) OC.

CALMEX SUPPLY INC. — Type S/L/T

METALITE INC. — The System

SCARCO STEEL SYSTEMS/CHURCH CO. — Stacked Track

TELLING INDUSTRIES L.L.C. — True-Action Deflector Track

A2. Light Gauge Framing\* — Vertical Deflection Ceiling Runner — As an alternate to the ceiling runner in Item 2A and 2A1, vertical deflection ceiling runner to consist of galv-steel channel with notched vertical deflection clips mechanically fastened within runner. Stacked clips, provided with steel brackets for permanent fastening of steel studs. Flanges used to accommodate steel studs (See 2B). Vertical deflection ceiling runner secured to concrete floor slab with steel fasteners or steel masonry anchors spaced max. 24 in. (610 mm) OC.

THE STEEL WORKING INC. — Notched VTDSD, VTDSD, VTDSD and VTDSD

A3. Light Gauge Framing\* — Notched Ceiling Runner — As an alternate to the ceiling runner in Item 2A through 2A3, notched ceiling runner to consist of galv-steel channel with notched flanges used to accommodate steel studs (See 2B). Notched ceiling runner secured to concrete floor slab with steel masonry anchors or steel fasteners spaced max. 24 in. (610 mm) OC.

CALMEX SUPPLY INC. — Type S/L/T

B. Studs — Steel studs to be min. 3 1/2 in. (89 mm) wide and formed of min. 25 ga galv-steel. Studs cut 24 in. (610 mm) to 19 in. (483 mm) less in length than assembly height with bottom flange in and secured to floor runner. Steel studs installed in ceiling runner without attachment. Studs spaced max. 24 in. (610 mm) OC.

C. Gypsum Board\* — Gypsum board 1/2 in. (13 or 16 mm) thick, applied on both sides of wall as specified in the individual Wall and Partition Design except that a max. 3/8 in. (9.5 mm) gap shall be maintained between the top of the gypsum board and the bottom of the floor assembly. The screws attaching the gypsum board to stud at the top of the wall shall be located 1 in. (25 mm) to 1 1/2 in. (38 mm) below the bottom edge of the ceiling runner. No gypsum board attachment screws shall be driven into the ceiling runner.

The finish surface of the joint system may equal the finish of the wall.

3. Fire, Void or Core Material\* — Top Track Seal — When min. separation between the bottom of floor and top of wall is 1/2 in. (13 mm), the joint system is designed to accommodate a max. 25 percent compression or extension from its installed width. When max. separation between the bottom of floor and top of wall is 3/8 in. (9.5 mm), the joint system is designed to accommodate a max. 60% compression only from its installed width. Fastener installed from wall installed over the ceiling runner (See 2C) prior to attachment to underside of concrete floor in accordance with the installation instructions.

HETI CONSTRUCTION CHEMICALS, DIV OF HETI INC. — OFS-TTS 306, OFS-TTS 600 or OFS-TTS-03

\* Indicates such products shall bear the UL or eUL Certification Mark for jurisdictions employing the UL or eUL Certification (such as Canada), respectively.

**UL** **UL**

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. December 21, 2015

Page 2 of 2

Notes:

1. Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - \* Minimum and maximum Width of Joints
  - \* Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
  - \* 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
  - \* Intertek Directory of Building Products
  - \* All governing local and regional building codes

Current as of November 19, 2017.  
System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current 'Underwriter's Laboratories Fire Resistance Directory (volume 2.)'

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 11-19-2017

REVISIONS: \_\_\_\_\_

SHEET NAME:  
Residential - Hollow Core - Gypsum Chase Wall

SHEET NUMBER: \_\_\_\_\_

**System No. HW-D-0268**  
**Assembly Rating - 3 Hr**  
**Nominal Joint Width - 1 in.**  
**L Rating At Ambient - Less Than 1 CFM/Lin Ft**  
**L Rating At 400°F - Less Than 1 CFM/Lin Ft**  
**Class II Movement Capabilities - 12.5% Compression and Extension**

1. Floor Assembly - Min 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete. Floor may also be constructed of any min. 6 in. (152 mm) thick, Class II, Classified Hollowcore Precast Concrete Unit.<sup>1</sup> See Precast Concrete Units (PCU) category in the Fire Resistance Directory for names of manufacturers.  
2. Wall Assembly - Min 8 in. (203 mm) thick clear reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete. Wall may also be constructed of any Class II, Classified Concrete Block.<sup>2</sup>  
3. Concrete Blocks (CB) Category in the Fire Resistance Directory for names of manufacturers.  
4. Joint System - Max separation between bottom of floor assembly and top of concrete wall at time of installation is 1 in. (25 mm). The joint system is designed to accommodate a max. 12.5 percent compression or extension from its installed width. The joint system shall consist of the following:  
A. "UL Void or Cavity Material" - Sealant - A 1/2 in. (13 mm) thickness of fill material installed within the joint, flush with each surface of the wall.  
B. "UL Void or Cavity Material" - Sealant - A 1/2 in. (13 mm) thickness of fill material installed within the joint, flush with each surface of the wall.  
C. Forming Material - (Optional, Not Shown) - Mineral wool insulation or polystyrene foam backer rod. Forming material to be recessed from both surfaces of the wall as required to accommodate the required thickness of fill material.  
<sup>1</sup>Bearing the UL Classification Mark  
<sup>2</sup>Bearing the UL Classification Mark

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. June 26, 2008

**System No. HW-D-0403**  
**Assembly Rating - 3 Hr**  
**L Rating at Ambient - Less than 1 CFM/Lin Ft**  
**L Rating at 400°F - Less than 1 CFM/Lin Ft**  
**Nominal Joint Width - 2 in.**  
**Class II Movement Capabilities - 8% Compression Or Extension**

1. Floor Assembly - Min 6 in. (152 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete.  
2. Wall Assembly - Min 8 in. (203 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) structural concrete. Wall may also be constructed of any Class II, Classified Concrete Block.<sup>2</sup>  
3. Concrete Blocks (CB) Category in the Fire Resistance Directory for names of manufacturers.  
4. Joint System - Max separation between bottom of floor and top of wall (at time of installation of joint system) is 2 in. (51 mm). The joint system is designed to accommodate a max. 8 percent compression or extension from its installed width. The joint system shall consist of the following:  
A. Forming Material - Min 4 pcf (64 kg/m<sup>3</sup>) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min. width of 5 in. (127 mm) and installed edge first to joint opening, parallel with joint direction. Each batt section are compressed no 50 percent in thickness and such that the compressed batt sections are recessed from both surfaces of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be tightly lapped with lapped seams spaced max 24 in. (610 mm) apart along the length of the joint.  
B. "UL Void or Cavity Material" - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint, flush with both surfaces of the wall.  
<sup>1</sup>Bearing the UL Classification Mark  
<sup>2</sup>Bearing the UL Classification Mark

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. September 20, 2002

Notes:

1. Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:  
  - \* Minimum and maximum Width of Joints
  - \* Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:  
  - \* 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
  - \* Intertek Directory of Building Products
  - \* All governing local and regional building codes

Current as of November 19, 2017.  
System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current "Underwriter's Laboratories Fire Resistance Directory (volume 2)."

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 11-19-2017

REVISIONS: \_\_\_\_\_

SHEET NAME:  
 Residential - Hollow Core - Concrete or Masonry Wall

SHEET NUMBER: \_\_\_\_\_