

Confirmation

LEED

On 22/03/2016, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

HIT-HY 70

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2016-00118503_H_EN and 392-2014-00149701rev1_01).

The test results of the tested product indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

29 April 2016



Janne R. Norup
Chemist



Thomas Bjerring
Analytical Service Manager